

**Commonwealth of Massachusetts
Department of Telecommunications and Energy
Fitchburg Gas and Electric Light Company
Docket No. D.T.E. 02-24/25
Responses to the Attorney General's Seventh Set of Information Requests**

Request No. AG-7-54 (Electric)

Referring to page 19 of Mr. Collin's prefiled testimony, please provide total MVA capacity of the Princeton Road Substation.

Response:

Princeton Road Substation currently has two power transformers, each with a nameplate rating of 12/16/20 MVA. Thus, the substation has capacity totaling 40 MVA.

Person Responsible: Mark H. Collin